

APPLICATION No.: 25560

TAP CLEARED

LOCATION: S.S. Hillman St., E x Chancery St.

OWNER: N.B. Vocational High School

MEASURES: 2" Copper 6-17-59
 1-2" Dar. Gate Valve O-ring, all bell, 1 R-144
 Caldwell valve box
 E from E line Chancery 69.4 ft.
 N from S line Hillman 6.8 ft.
 E from W line Fence 3.0 ft.
 Main is 14 ft. N x S line

May 8 & 9, 1963 Repaired a broken 2" broken gate valve
 by replacing the spindle.
 2" Darling o-ring spindle 1 gasket
 - - -

DATE BEF. AFT. REMARKS

[illegible]

CHARGE OUTS

[illegible]

APPLICATION No.: 25560

TAP CLEARED

LOCATION: S.S. Hillman St., E x Chancery St.

OWNER: N.B. Vocational High School

MEASURES: 2" Copper 6-17-59
1-2" Dar. Gate Valve; all bell \emptyset -ring, 1 R-144
Caldwell valve box
E from E line Chancery 69.4 ft.
N from S line Hillman 6.8 ft.
E from W line Fence 3.0 ft.
Main is 14 ft, N x S line

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]