

APPLICATION No.: 25572 3/4" copper

TAP CLEARED

LOCATION: 3792 Acushnet Ave.

OWNER: Manual Perry Jr.

MEASURES: 3/4" copper July 29, 1959
 N from N line Churchill 1.4 ft.
 W from E line Acushnet Ave. 5.8 ft.
 S from N line House 5.7 ft.

September 10, 1974 Renpaired leak 2 ft. inside curb stop
 to a point 4 ft. - Broken by D.P.W.
 2 ft. - 3/4" Copper tubing 2 - 3/4" Cop. cplg.

10/12/07 - NE Pressure Project - Tied service into new 12" main.
 Renewed from main to a point 2 ft.
 Stock: 2 ft - 3/4" copper tubing; 1 - 3/4" x 3/4" cop to cop cplg.
 comp. Broke sewer main - repaired 3.5 ft - 10" PVC pipe and 2 -
 10" PVC to PVC Fern Coats D. Monty

DATE

BEF.

AFT.

REMARKS

METER HISTORY

CHARGE OUTS

[illegible]