

APPLICATION No.: 25590

TAP CLEARED

LOCATION: Purported 121 North St

DATE

BEF.

AFT.

REMARKS

OWNER: P. 58 L. 259A

31-313

MEASURES:

Contractor Farland Corp renewed and relocated service from curb stop in. 06.07.2023

Inspector Percy Reynolds

6" Ductile Iron

E X E Line Summer St 96.5'

N X N Line North St 7.8'

E X E Line Building 8'

S X S Line Building 8'

Pipe Inside property 45'

METER HISTORY

[illegible]

CHARGE OUTS

APPLICATION No.:

25590

LOCATION:

N.S. 121 North St E x Summer St

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

OWNER:

31-313

MEASURES:

FIRE SUPPLY 6" CAST IRON 9-10 & 11-59

6" Darl. Tap. Gate. R-Cast Iron Gate Box

E from E line Summer

97.5 ft

N from S line North

15.5 ft

E from E line Bldg. High School

9.0 ft

November 22, 1975 Renewed from the new 30" main in North St to a point 4 ft from property line

30" X 30" X 6" C.I.C.L. Class 250 Tee, M.J.

20.2 ft. – 6" C.I.C.L. Class 2 Ductile Pipe

6" U.S. Private gate valve, M.J.

Buffalo gate box

2-6" C.I.C.L. Class 250 1/8 Bends M.J., 1-6" C.I.C.L. Class 250 Solid Sleeve, 8-6" Pipe

Straps complete with dogs

28 ft. - 5/8" threaded rod

Measure of 6" private gate valve

E X E Line Summer 97.2 ft

E X E Line west school 8.2 ft

N X S line North St 18.5 ft

S X N line North St 21.5 ft

Measure of north 1/8 bend

N X S line North St 26.0 ft

E X E line Summer St 97.2 ft

Measure of south 1/8 bend

N X S line North St 23.0 ft

E X E line Summer St 97.2 ft

Measure of 6" solid sleeve

S X N line North St 4.0 ft

E X E line Summer St 97.2 ft

[illegible]