

Theo H. Rice Blvd.

APPLICATION No.: 25624

LOCATION: N.S. Braley Rd., Ext. W x Braley Rd.

OWNER:

FIRE SUPPLY

MEASURES:

6"

C.L. Cast Iron

9-23,24,25,1959

6" Dar. Tpg. Gate-6" C.I. Gate Box

W from 2nd hydr. W x Phillips Rd.

59.8 ft.

W from W line

Building

8.2 ft.

s from S line

Building

127.0 ft.

Oct. 7, 1997 Gioioso Cont repaired leak caused by settlement of trench which was excavated under main.

Installed a 6" Smith Blair #227 DB Clamp cplg. supplied by Contractor at a point N x 6" gate valve 41.0 ft. Insp. by M. Rose III

TAP CLEARED

DATE

BEF.

AFT.

REMARKS

[illegible]