

APPLICATION No.: 25676

TAP CLEARED

LOCATION: N.S. #9 Pope St. W x Pleasant St.

DATE

BEF.

AFT.

✓ REMARKS

OWNER:

MEASURES: 1-6" Dar. Tap Gate; 1-6" C.I. Gatebox 224#
W from W line Pleasant St 111.5
N from S line Pope 16.3
E from E line building 5.4

12/20/78: Repaired leak on 6" fire supply by replacing
the 6"-#441 Cplg. that was previously installed during
Cement Lining Project.

F
I
R
ES
U
P
P
L
Y

[illegible]

CHARGE OUTS

[illegible]