

SERVICE (Industrial Properties Inc.) Application No. 25737
 St. & No. W. S. Orchard St., N x Cove Rd. (P. 19)

Size Pipe 2" Kind Pipe Copper May 6th 1960
 1-2" Dar. Gate Valve; 0-ring, 1 R-144 Caldwell valve

N from N line Cove Rd. St. 463.5^{box} ft.
 E from W line Orchard St. 9.7 ft.
 S from N line Bldg. SER. DISCONTINUED 69.7 ft.
 S x 2nd hydt. N x Cove Rd. 80.0

City

ft. Earth	Taker	ft. Earth	35	28
ft. Pipe	labor	ft. Pipe @ 1.86	111	60
		DISCONT.		
		SER. REMOVED		
		5-9-2002		
		total	306	98

Handwritten: 8-19-60, 8-24-60, NB888

S-9-2002: THE OLD 2" DART GATE VALVE
PACKING FLANGE ROTTED. REMOVED 2" GATE
VALVE. INSTALLED A 2" CURB STOP, LEFT
COP. DISCONNECTED FROM CURB STOP 2.0 FT
IN FRONT OF STOP ALSO LEFT NEW CURB
STOP BURIED WITHOUT BOX.