

APPLICATION No.: 2577

TAP CLEARED ✓

LOCATION: 59 Spruce

OWNER: Elaine Antone

MEASURES: 3/4"

N from	Maxfield	117.2 ft.
E from W line	Spruce	6.2 ft.
N from S line	House	3.2 ft.

-----  
September 11, 1953 Renewed from curb stop to inside the cellar.  
15 ft. of 3/4" copper tubing 1 wipe joint  
-----

August 11, 1952 Repair leak in curb stop inside joint.  
1 lb. of wiping solder.  
-----

3-2-99 Renewed from main to curb stop, Stock:  
10 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop,  
1 - Caldwell Stop Box, 1 - 3/4" x 3/4" Fig. 413,

DATE

BEF.

AFT.

REMARKS

3-2-99 1999/001607

3-2-99 Tap reamed

[illegible]

## CHARGE OUTS

[illegible]