

713 APPLICATION No.: 25781
LOCATION: N.W. Cor. Shawmut Ave. E Coggeshall St.

OWNER: Leon Gordon

MEASURES: 6" C.I. Cem Lined 6-29&30-60
1-6" Tap Gate Valve; O-Ring Dar; 1-6" C.I. Gatebox 224#
S from S line Topham 11.6 ft.
E from W line Shawmut Ave. 13.4 ft.
N from S line Building 16.2 ft.

FIRE SUPPLY

July 23, 1984 This fire supply was broken by walsh Co.
when hooking up for cement lining.

2.1 ft. - 4" ductile pipe, 1 - 4" dresser epair cplg.
2 leadite joints 6" x 4" reducer, B & S

11/20/07 - Owner charged \$60.00 (\$30 for shut-off & \$30
for turn-on) for Dartmouth Fire Protection to replace
main shut off valve. Percy Reynolds

TAP CLEARED

DATE BEF. AFT. REMARKS

[illegible]

CHARGE OUTS