

APPLICATION No.: 25951

TAP CLEARED

LOCATION: N.S. Braley Rd. Ext., W x Braley Rd.

OWNER: Alberox Corp.

FIRE SUPPLY

MEASURES: 8"

8" C.I. Cem Lined 7-17-20, 61
1-8" Dar. Gate Valve, tap (O R) 1-6" C.I.

1-8" Dar. Gate Valve, tap (O R) 1-6" C.I.

Gatebox 224#

E from E industrial Park Rd.

83 ft.

N from S line

Braley Rd.

24.4 ft.

E from W line

Building

2.3 ft.

August 18, 1997 Gioioso Cont. repaired 8" joint leak on this fire supply. Main undermined by sewer project.

Installed 1 - 8" Smith Blair # 274 Bell jt. clamp - N x 8" gate valve 37.0 ft.

[illegible]

CHARGE OUTS

[illegible]