

Theo H. Rice Blvd.

APPLICATION No.: 25952

TAP CLEARED

LOCATION: N.S. Braley Rd. Ext., W x Braley Rd.

OWNER: Alberox Corp.

MEASURES:	3"	Copper	7-17-20, 1961
	1-3" Dar. Tap. Gate Valve;	1-4" C.I. Gatebox	209#
	E from E line	Industrial Park Rd.	85.3 ft.
	N from S line	Braley Rd.	24.4 ft.
	E from W line	Building	4.2 ft.

Aug. 18, 1997

Gioioso Cont. repaired 3" leak - pulled sweat joint on this 3" service. Ser. undermined by sewer project.

Installed :

1 - 3" Smith Blair #226 Clamp Cplg. 12½" W  
2.97-3.25 OD

Repaired at a point 20.8' N x 3" gate valve.

[illegible]



RICE BLVD.

APPLICATION No.: 25951

## TAP CLEARED

LOCATION: N.S. Braley Rd. Ext., W x Braley Rd.

OWNER: Alberox Corp.

FIRE SUPPLY

MEASURES: 8"

C.I. Cem Lined

7-17-20,61

1-8" Dar. Gate Valve, tap ( O R) 1-6" C.I.

Gatebox 224#

E from E industrial Park Rd.

83 ft.

N from S line

Braley Rd.

24.4 ft.

E from W line

Building

2.3 ft.

August 18, 1997 Gioioso Cont. repaired 8" joint leak on this fire  
supply. Main undermined by sewer project.

Installed 1 - 8" Smith Blair # 274 Bell jt. clamp - N x 8" gate valve 37.0 ft.

-----

[illegible]

## CHARGE OUTS

[illegible]