

APPLICATION No.: 25956

## TAP CLEARED

LOCATION: N.S. 967 Peckham Rd. E x Acushnet Ave.

DATE

BEF.

AFT.

REMARKS

OWNER: Joseph W Pacheco

10/5

9540-05003

## MEASURES:

3/4"

Copper

8-7&amp;8-61

W from W line

Upland

~~238.1 ft.~~

238.0

S from N line

Peckham Rd.

~~7.7 ft.~~

7.5

W from E line

House

~~4.2 ft.~~

16.4

S from S line

House

~~44.0 ft.~~

42.7

Line to main is 32 ft.

10/5/95: tap reamed

8-18-88= BLOCKED METER REMOVED...

Oct 5, 1995:

REnewed from main to a point 18 inches

Stock: 18 inches 3/4" copper tubing

1-3/4x5/8 Fig 413

=====

5/27/09 - North End Pressure Project - City crew renewed service  
from new 8" water main to a point 4 ft

4 ft - 1" copper tubing; 1 - 1" x 1" cop to cop cplg. comp

Foreman: Dana Farland

-----

[illegible]