

APPLICATION No.: 25960

TAP CLEARED

LOCATION: N.S. 907 Peckham Rd. E x Upland St.

DATE

BEF.

AFT.

REMARKS

OWNER: A. Plante

MEASURES: 3/4"

Copper

8-10-61

E from E line

Upland

321.2 ft.

S from N line

Peckham Rd.

4.7 ft.

Dec. 23, 1974 Renewed from a point 2 ft. s x property
line to a point 6 ft. from the property line.

4 ft. - 3/4" Copper tubing 3/4" Coupling (at point
Dresser 313 cplg. - supplied 2 ft. s x prop. line)
by Fantoni

Fantoni Cont. broke this service. They will maintain
trench.

- - -

E x E line Upland St.

322.9 f t.

S x N line Peckham Rd.

7.0 ft.

W x E line house

2.0 ft.

S x S line house

40.7 ft.

6/5/09 - North End Pressure Project - City crew tied water service
into new 8" water main in Peckham Rd - Renewed service from new
8" water main to a point 5 ft
5 ft - 3/4" copper tubing; 1 - 3/4" x 3/4" cop to cop cplg comp
Foreman: Dana Farland

[illegible]

CHARGE OUTS

[illegible]