

APPLICATION No.: 2599

TAP CLEARED

LOCATION: 46 Crapo St

DATE

BEF.

AFT.

REMARKS

OWNER:

31-313

7/19/95 Tapped

MEASURES: July 18, 1876

S X Rockland St 112.5 ft

W X E line Crapo St 6.6 ft

N X S line House 8.0 ft

1" Copper service

10/31/2018 Lead service line replacement program

Phase 1, Contractor P. Gioioso & Son

Type CU, Diameter (in) 1, Water Pressure 90

Distance from main to curb stop (ft) N.A

Distance curb stop to meter (ft) 15

Distance from curb face to curb stop (ft) 1.5

Depth of service (ft) 3.3

Total length of new pipe installed (ft) 15


Curb stop replaced: no

Corporation replaced: no

Ball valve replaced: yes size 1"

[illegible]

CHARGE OUTS



APPLICATION No.: 2599

TAP CLEARED

LOCATION: 46 Crapo St.

OWNER: Domingos Samagalo, Et Ux

MEASURES: 5/8" H lead July 18, 1876

S from Rockland St. 112.5 ft.

W from E line Crapo St. 6.6 ft.

N from S line house 8.0 ft.

Aug. 18, 1958 Renewed 6" outside curb stop to 1" 6" inside curb
stop 2 ft. of 3/4" copper tubing
3/4" cop. stop fig. 415 2# Solder

JULY 19, 1995: Crapo St. Reconstruction

Todesca Corp renewed service from the main to prop line
Cont. supplied all stock & will maintain trench

Stock: 27ft - 3/4" copper tubing 1-3/4" curb stop

1-Caldwell stop box 1-3/4x5/8 lead-cop adapt.xxs

1-3/4x5/8 Fig 413

Insp. D.Monty NOTE: copper goes over sewer 2 1/2 ft road cover.
copper insulated

ADDITIONAL MEASURES:

S x N line house 18.0ft

N x S line house 8.0ft

5/4 & 5/5/06 Sewer repair...replaced 16 ft. 6" clay pipe with
16 ft. 6" PVC. Foreman: Cornell

DATE BEF. AFT. REMARKS

7/19/95 tap reamed

[illegible]

CHARGE OUTS