

APPLICATION No.: 26253LOCATION: 31 N.W. Cor. Holly Tree Lane & Greenbrier DriveOWNER: Ralph D. Souza

MEASURES: 1"

W from W line

S from N line

E from W line

S x S line house

Main is 3 ft. S x N line

Copper

Greenbrier Drive

Holly Tree Lane

House

4-25-63

54.3 ft.

6.8 ft.

3.7 ft.

33.5 ft.

TAP CLEARED

DATE

BEF.

AFT.

REMARKS

*measures do
not agree
with
attached card*

April 4, 1972 Renewed from the curb stop to inside
cellar. This service was leaking due to the copper
tubing being in a pitted conditon.
This service was originally installed April 25, 1963
42 ft. - 1" Copper tubing

- - -

