

APPLICATION No.: 26931

TAP CLEARED ✓

LOCATION: S.E. Cor. 860 Tradewind & Oakdale Sts.

DATE

BEF.

AFT.

REMARKS

OWNER: Rockdale Country Estates Inc.

MEASURES: 1" Copper April 22, 1965

S from S line	Oakdale	16.0 ft.	10 ft.
W from E line	Tradewind	7.4 ft.	7.1 ft.
N from N line	House	33.6 ft.	
Line Service			

W x W line House 29.0'

Oct. 24, 1979 Repaired leak caused by Contractor while
installing sewer (Capaldi) - Repaired leak by installing
a 1" x 1" Compression cplg.

Measure of cplg: W x curb stop 14 ft.
E x Tap 6"

[illegible]

CHARGE OUTS

APPLICATION No.: 26931

TAP CLEARED

LOCATION: S.E Cor. 860 Tradewind & Oakdale St.

OWNER:

MEASURES: 1"

Copper

April 22, 65

S from S line Oakdale

16.0 ft.

W from E line Tradewind

7.4 ft.

Line service.

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]