

SERVICE Grossman Ind. Prop. Inc. Application No. 27016

St. & No. ³⁸⁷ W. S. Church St., S x Carlisle St.

Size Pipe	Kind Pipe	Laid
6" S	C. L. C. I. Tapping Gate Valve ORing	August 2 & 3, 1965
from S line	Carlisle St.	St. 112.2 ft.
E from W line	Church St.	St. 19.0 ft.
N from S line	building	St. 59.0 ft.

Main is 18' E x W line

City	ft. Earth	Taker	ft. Earth
	ft. Pipe	18'-6"	ft. Pipe
113 N.B. 93			45 00
113			480 80
		Total bill	

FIRE SUPPLY

1-22-94 The 6" fire supply gate valve was shut off & gate box removed. Cut the 6" line at a point 5ft. W x tapping gate valve & installed a 6" mech. plug. E x W line church st. 14ft st. cut 9' x 4' Warrenite

1-28-94 Water still coming up in street. Installed a 6" Rockwell #441 Cplg. w/steel plate on 6" line coming back from line. Capped just west of 6" mech. plug.