

APPLICATION No.: 2720

TAP CLEARED

LOCATION: 298 County St

OWNER:

31-313

MEASURES: 1" Copper Service

6/3/2019 - Lead Service Line Replacement Program

Phase 1, Contractor P. Gioioso & Son

Type CU, Diameter (in) 1, water pressure 100

Distance from main to curb stop (ft) n/a

Distance curb stop to meter (ft) 15

Distance from curb face to curb stop 1.5

Depth of service (ft) 4

Total length of new pipe installed (ft) 15

Curb stop replaced: no, corporation replaced: no


Ball valve replaced: yes, size 1"

DATE

BEF.

AFT.

REMARKS

[illegible]

APPLICATION No.: 2720

TAP CLEARED ✓

LOCATION: 298 County St.

OWNER: George T.G. Lee Et. Ux

MEASURES: 3/4" 5/8"

Copper

Dec. 9, 1876

N from

Sherman St.

34.0 ft.

W from EAline

County St. 4.0' 8.2 ft.

N from S line

house

3.2 ft.

✓ Oct. 16, 1964 Renewed service from main to 3 ft. inside curb stop
27 ft. 3/4" copper tubing

1 3/4" cop. to copl to cop. stop. fig 415

1 5/8" reused corporation coupling

1 lb. wiping solder

1 Caldwell stop box, complete - long

Tap reamed

125 compressor 3 hr.

Oliver Loader 2 hr.

2 street cuts: 8' x 2' & 6' x 2' Warrenite

1 sidewalk cut: 5' x 2' Blacktop

Abraham, Frasier, Rapozo

✓ May 9, 1975 Renewed from a point 10 ft. east of the main
to a point 17 ft. east of the main.

7 ft. - 3/4" Copper tubing 3/4" curb stop

3/4" x 3/4" Cplg.

✓ June 11, 1975 Renewed from the curb stop to the prop.
line.

9 ft. - 3/4" Copper tubing 3/4" Curb stop

5/8" x 3/4" lead connector - - -

BRADBURY-WARING, INC.

1-27-92

REQUEST RENEWAL - TO

CHECK W/ PLUMBER FIRST!

[illegible]

CHARGE OUTS