

APPLICATION No.: 27222

TAP CLEARED

LOCATION: W.S. 1533 Padanaram Ave. S x Cove Rd.

DATE

BEF.

AFT.

REMARKS

OWNER: Joseph Arsenault

MEASURES: 3/4" Copper 4-22-66
 S from S line Cove Rd. 486.2 ft.
 E from W line Padanaram Ave. 7.8 ft.
 S from N line House 0.4 ft.
 E from E line House 33.9 ft.
 Main is 18 ft. E x W line.

 February 10, 1967 Tap blew out of 8" C.I. main pipe.
 Massey Ferguson Loader and backfilling 1 hr.
 Renewed from main to a point 5 ft. from main.
 1 8" Adams clamp. #814-8-915 1 3/4" corp. tap. Mueller
 5 ft. 3/4" copper tubing used. Total 3/4" cop cplg.
 (old 3/4" corp. tap. was returned to the repair shop.)

February 15, 1967 Adams repair sleeve was removed from this
 location and the 8" main C.I. pipe was tapped.
 3 ft. 3/4" copper tubing used. 1 3/4" corp. tap. (Reused)
 N.B.W.W. tapping machine #1 1 3/4" cop. to cop. coupling

March 24, 1982 Tied into new 8" main.
 1 - 3/4" Corporation 3 ft. - 3/4" Copper tubing
 1 - 3/4" Cop to cop cplg.
 - - -

[illegible]

CHARGE OUTS

[illegible]