

4891 43 COUNTY RD.

APPLICATION No.: 27308 1" copper

TAP CLEARED

LOCATION: 4901 Acushnet Ave. Box

OWNER: Mrs. Raymond DeCosta

MEASURES: 1" CopperNorth Meter Sept. 28, 1966
 S from 1st hyd. from junction of Webbs Cr. 251. 1 ft.
 E from W line Acushnet Ave. 6.7 ft.
 S from N line Meter Box 4.5 ft.
 E from E line Meter Box 16.5 ft.
 Main is 36 ft. E x W line.

Aug. 21, 00 Complaint of poor pressure.

Dec. 5, 2000 Pressure checked by J. Rezendes 40 #

Dec. 7, 2000 Pressure checked by Gil Souto 38 #

State Permite had been applied for - but will not ream tap - pressure for area is good.

DATE

BEF.

AFT.

REMARKS

2000 480 3377v

Clear 11/27

METER HISTORY

CHARGE OUTS

[illegible]