

APPLICATION No.: 27479

TAP CLEARED

LOCATION: W.S. 785 Mt. Pleasant St. S x Downey St.

OWNER: Charles Sylvia

MEASURES: 3/4" Copper 5-10-67

S from S line Downey St. 74.9 ft.

E from W line Mt. Pleasant St. 8.0 ft.

N x N line house 0.5 ft.

E x E line house 15.4 ft.

Main is 30 ft. E x W line.

March 12, 1986 This service does not feed this house. This house is fed by 1" # 28378. This service is either shut off at tap or disconnected at tap. The curb stop was removed and no water comes in from main. This service also goes straight from curb stop straight up to north corner of house. The cement has to be broken up to check any further.

1 Caldwell Stop box, complete.

 note: Controlling curb stop for this service is #28378.

May 12, 1993 Ser. # 27479 - Must be off at main - Removed this stop box
 Disconnected & took out tee (which was tied into #28378. Left curb stop
 inground.

DATE

BEF.

AFT.

REMARKS

DOWNEY ST.

28378

20910

27479

[illegible]

CHARGE OUTS

[illegible]