

APPLICATION No.: 2805 3/4"

TAP CLEARED 9008-1396

LOCATION: 95 Court St.

OWNER: Frank H. Macy

MEASURES:

~~3/4" 1"~~

E from

Cedar

70.4

70.7 ft.

S from N line

Court

5.5

7.1 ft.

E from W line

House

6.3

6.5 ft.

S x S line

"

18.2

Sept. 24, 1974 Renewed from the main to a point 9 ft. from the main. The old 3/4" Tap blew out and a new 1" tap was installed.

8 ft. - 3/4" Copper tubing 1 ft. - 1" Copper tubing

1" McDonald tap

3/4" x 3/4" Ford lead to cop. adaptor XS  
(9 ft. from the main)

1" x 3/4" Cop to cop reducing cplg.

Leak caused by settling of sewer trench

Federico supplied the stock, labor, excavated & will maintain trench

- - -

Nov. 7, 1974 Renewed from the new 16" main in Court St. to the property line.

✓ 26 ft. - 3/4" Copper tubing 3/4" McDonald tap

3/4" McDonald curb stop Buffalo stop box

3/4" x 3/4" Ford lead to cop. adapt. XS (at prop. line)

- - -

✓ Feb. 22, 1990 Renewed from curb stop to a point 1 ft. inside curb stop. 1 - 3/4" curb stop 1 ft. - 3/4" copper tubing

1 - 3/4" x 3/4" cop to cop cplg., comp.

Could not shut off service for leak inside house - broken keyway on cold

curb stop - had to be dug

DATE

BEF.

AFT.

REMARKS



## METER HISTORY

[illegible]

## CHARGE OUTS

om prop. line before

APPLICATION No.: 2805

## TAP CLEARED

LOCATION: 95 Court St.

DATE

BEF.

AFT.

REMARKS

OWNER: Mark Bryant

Lot #261

31-313

MEASURES:

1"

Copper

Jan. 1, 1887

New measures:

E x E line Cedar St.

71.0 ft.

S x N line Court St.

6 ft. 8 in.

W x W line house

3 ft. 4 in.

S x S line house

28.0 ft.

9/27/03 Contractor renewed from property line to  
meter inside. 3/4" to 1" inside.

-----



[illegible]

## CHARGE OUTS

[illegible]