

c/o Armand O. Demanche, U.A. Local #77, 55 6th St.
Tel. 3-7783 New Bed. *MT*

September 17, 1970

124

#28284

Airport Commission

E.S. Shaw. Ave., S. x Old Plain. Rd.

Please install 6" C.I.C.L. FIRE SUPPLY service
to supply SCHOOL.

Measures of 6" FIRE SUPPLY:

S x S line	Plainville Rd.	1032.0 ft.
E x W "	Shawmut Ave.	19.0 ft.
N x S "	Building	57.4 ft.
W x W "	"	60.1 ft.

Work done Oct. 20, 1970

Owner supplied & Installed all stock
62 ft. of C.I. Tyton Pipe Used

Owner dug, backfilled & will maintain
trench cuts.

Inspected by Frank Frasier

1-8"x8"x6" Tapping Sleeve - A. P. Smith
1-6" Tapping Gate Valve - A. P. Smith
1-6" C. I. Gate Box, Complete
14 lbs. Mineralead
1 lb. Gasket Material