

Tel. 9-5026

414 County St. 133 *mm*

November 10, 1970

Nationwide Developers Inc./E.J.  
Sylvia

#28354

W.9. Seabury St., N x Irvington  
St. (*North House*)

Please install 1" copper to supply cape  
cottage. on existing main/ lay with drain  
Meter: inside cellar wall.

Measures of 1" Curb Stop:

|                          |           |
|--------------------------|-----------|
| N x N line Irvington St. | 132.0 ft. |
| E x W " Seabury St.      | 6.0 ft.   |
| S x N cor. House         | 14.0 ft.  |
| E x E " "                | 21.0 ft.  |

Main is 18 ft. E x W line.

Work done Dec. 1, 1970

*L A I D W / D R A I N*

|                                                |          |
|------------------------------------------------|----------|
| 35 ft. - 1" Copper by Owner: 18' out: 17' ins  |          |
| Labor. . . . .                                 | \$ 40.78 |
| 1 1/2" Hays Corporation . . . . .              | 8.50     |
| 1 1/2" Hays Curb Stop. . . . .                 | 14.00    |
| 1 Buffalo Stop Box, complete. . . . .          | 10.00    |
| Carting . . . . .                              | 10.00    |
| D-4 Drilling Machine Use . . . . .             | 15.00    |
| 2 1" Meter cplg. @ 2.50 ea. . . . .            | 5.00     |
| 6" x 1" Dresser Style 91 D.S. Saddle . . . . . | 10.56    |
| Loader Use: 2 hrs. @ 7.00 hr.. . . .           | 14.00    |
|                                                | <hr/>    |
|                                                | 127.84   |