

APPLICATION No.: 2842

TAP CLEARED

LOCATION: 50 Dartmouth St.OWNER: John R. Andrade Et Ux

DATE

BEF.

AFT.

REMARKS

11/12/77

Reamed ✓

MEASURES: 5/8"

H lead

June 9, 1877

N from

Grinnell St.

164.5 ft.

W from E line

Dartmouth St.

7.8 ft.

N from S line

house

9.3 ft.

March 4, 1976 Renewed from 6" outside curb stop to
inside cellar.

12 ft. - 3/4" Copper tubing (4 ft. inside)

3/4" Curb Stop Caldwell Stop Box

5/8" x 3/4" lead to cop. adaptor XXS

11/5/77: Leak at tap. Renewed from main to inside cellar
wall. 24 ft. - 3/4" copper (8 ft. ins. Supp. by Owner);
1/2" x 3/4" Figure 413;

[illegible]

CHARGE OUTS