

Tel. 2-6100

414 County St.

70
of

July 27, 1971

#28479

Mass. General Housing Corp.

70

E.S. Caroline St., n. x Parker St.

Please install 4" C.I.C.L. 3" Taker's Meter service to supply 64 unit elderly housing. Serv. from Caroline St., Meter inside pit on Taker's land.

Measures of 4" Darling Gate Valve:

N x N line	Parker St.	272.0 ft.
E x W ^E	Caroline St.	21.0 ft.
S x S "	Bldg.	18.0 ft.
W x W "	Bldg.	55.5 ft.


Main is 32 ft. ~~E~~ x ~~W~~ ^E line.

Work done Jan. 5-6, 1972

34.6 ft. - 4" C.I.C.L. @ 1.78'.....	\$	61.59
2.3 ft. - 8" C.I.C.L. @ 4.01'.....	\$	9.22
labor.....	\$	251.68
4" Darling Gate Valve A.B.....	\$	56.40
4" Gate Box, regular pattern.....	\$	67.72
8" Smith Blair Style #441 cplg.....	\$	21.48
Painting.....	\$	20.00
8"x8"x4" C.I.C.L. Tee.....	\$	38.63
4" - 18" C - C Offset.....	\$	53.40
4" Pipe Strap.....	\$	7.00
6" Pipe Strap.....	\$	7.50
5# Mineralead @ .24#.....	\$	3.84
1# Asb. Yarn. Rope @ 2.28#.....	\$	2.28
oader 5 hrs. @ 7.00 hr.....	\$	35.00
t. cut: 32' x 3' Bit. Grav. @ .89'+5.--		33.48
Sidewalk cut: 8' x 3' Dirt.....		50.34
	\$	719.56

Service #28479 - 4"

Jan. 6, 1972



Measures of 8" Smith Blair #441 Cplg.:

N x N line Parker St. 275.3

E x W " Caroline St. 18.0