

45 APPLICATION No.: 28592

LOCATION: N.E. cor. Roseanne St. & Pamela Dr.

OWNER: Hia Pearl Corp.

NOT 27

TAP CLEARED



DATE	BEF.	AFT.	REMARKS
6/3/02	9 AM		2002-2300361

MEASURES: 1" March 24, 1972

E from E	Roseanne St.	65.0 ft.
S from N	Pamela Dr.	7.0 ft.
W from E	House	4.6 ft.
S from S	House	32.0 ft.

Main is 36 ft. S x N line.

-----  
August 3, 1972 Repaired a loose coupling by reflarring the copper tubing and tightening the corporation coupling.  
No stock used.

-----  
6/2/02 Renewed from prop line to a point 20 ft. ins. prop.  
Stock: 20 ft. 1" copper tubing; 2 - 1" x 1" cop-cop cplg., comp.

-----  
6/3/02 Renewed from main to a point 2 ft. in front of the main.  
Stock: 2 ft. 1" copper tubing; 1 - Caldwell stop box (Re-used old curb stop box); 1 - 1" x 1" cop-cop cplg., comp.; 1 - 1" x 1" Fig. 413  
Tap Reamed  
-----

[illegible]