

700 BELLEVILLE AVE
 454 APPLICATION No.: 28744

TAP CLEARED

LOCATION: E.S. Belle. Ave. opp. Covell St.

DATE

BEF.

AFT.

REMARKS

OWNER: Acushnet Co.

MEASURES:

4"

Oct. 25, 26, 30, 1972

S from S

Covell St.

5.3 ft.

E from W

Belleville Ave.

21.5 ft.

N from S

Bldg.

52.0 ft.

W from W

Bldg.

50.0 ft.

ADDRESS CORRECTION

PER D.D.W. 7/3/96

July 23, 1976 Repaired leak on leadite joint 17.6 ft.
 W x W line Foundation of Acushnet Co. factory.
 4" Smith Blair Bell Clamp (#271 4.80) 3# lead wool
 Side. 8' x 8' Cement

- - -

1976 Installed 4" Mueller service gate valve:
 S x S line Covell St. 1.6 ft. CAMARA
 E x W line Belleville Ave. 29.0 ft.

[illegible]