

APPLICATION No.: 28927

TAP CLEARED

✓

LOCATION: S.W. Cor. Conway St. & MacArthur Dr.

OWNER: Maritime Stevedoring FIRE SUPPLY

MEASURES: 6" C.I.C.L. August 9, 1973

E x E line MacArthur Dr. 94.5 ft.

S x N " Conway St. 1.2 ft.

E x E " Bldg. 17.0 ft.

S x S " Bldg. 26.0 ft.

Main is 1.2 ft. S x N line.

10/31/06 Repaired fire supply using 1 - 8" wraparound #226  
16 ft S x 8" shut off for fire supply Bento

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

|          |      |               |
|----------|------|---------------|
| 10/24/06 | 1 PM | 2006-440-3845 |
|----------|------|---------------|

[illegible]

## CHARGE OUTS