

APPLICATION No.: 28990

# TAP CLEARED

LOCATION:

S.S. Blackmer St. Ex So. First St.

OWNER:

J. Lawrence Nebel

MEASURES: 4"

CICL

Nov. 1, 2, 1973

E from E line	So. First St.	35.4 ft.
N x S	line Blackamer St.	14.0 ft.
E x W	line Bldg.	29.9 ft.
N x N	line Bldg.	21.4 ft.

Nov. 29, 1983 J.F. Kennedy Hwy Proj. This service has been changed over from the old 12" main to a new 8" ductile iron main.

Stock installed in this order:

8" x 8" x 4" Tee, mech.

6 ft. - 4" ductile pipe

4" Gate Valve, mech. (rodded & truss blocked)

2 ft. - 4" ductile pipe

1 - 4" 1/8 Bend, mech. (facing South west)

1.5 ft. - 4" ductile pipe

1 - 4" 1/8 Bend, mech. (south)

3 ft. - 4" ductile pipe

4" smith Blair #441 cast cplg.

Tie in to existing service 2 ft. south x S line Blackmer St.  
inside property Insp. j. Rodrigues

Measures of 4" gate valve:

E x E line So. First St. 36.3 ft.

N x S line Blackmer St. 5.5 ft.

N x N line bldg. 13.2 ft.

[illegible]

## CHARGE OUTS

[illegible]