

APPLICATION No.: 2914

TAP CLEARED 8327-14/4

LOCATION: 120 Parker

OWNER: Robert J. Durant

MEASURES:

3/4"

W from

Shawmut Ave.

108.1 ft.

N from S line

Parker

6.5 ft.

W from E line

House

1.3 ft.

FEB 2 - 1983 -- Renewed from main to 3 ft. outside main.
3/4" x 3/4" Fig. 413; 3/4" x 3/4" lead-cop. adapt. XXS;

July 11, 1983 Renewed 4 ft. from main. (SPECIAL)
4.7" 3/4" copper 1-3/4" x 5/8" lead-cop. adapt. XXS
- - - - -

Feb. 2, 1983 NOTE: Tap is 4 ft. east of curb stop.

5-3-01 Renewed from main to property line. Stock:
12 ft. -3/4" Copper tubing, 1-3/4" Curb Stop,
1-Caldwell Stop Box, 1-5/8"x3/4" lead to cop. adapt. XXS
1-3/4"x3/4" Fig. 413.

DATE

BEF.

AFT.

REMARKS

2/2/83

Reamed

Tap reamed 5-3-01

[illegible]

CHARGE OUTS

[illegible]