

APPLICATION No.: 29205-C

TAP CLEARED

LOCATION: Park Dept. Elephant Pool - So. of Court S t.

DATE

BEF.

AFT.

REMARKS

OWNER:

MEASURES: 1" Copper June 5, 1985

North of manhole 36.0 ft.  
 S x N line Elephant house 10.0 ft.  
 W x E line Elephant house 39.0 ft.  
 E x box to main 159.0 ft.



Dec. 23, 1985 Replaced broken gate box. dug by DPW  
 1 - Buffalo Gate Box

July 2, 1985 Emilys old house - Repairs to 1" copper service.  
 Cut out 12 ft. pc. of 1" copper and replaced with a new 1"  
 curb stop.

12 ft. - 1" copper tubing 1" curb stop with waste - Mueller  
 1 Caldwell stop box, 1" cop to cop compression cplg.  
 E x Emilys old house 25.0 ft.  
 S x N line Emilys old house 7.0 ft.

Nov 20, 1996: Repaired leak at elephant cage at approximately  
 12ft W x curb stop repaired copper service. Leak at wheel  
 valve inside fence. Stock: 1.0ft 1" copper tubing  
 1- 1" curb stop 1-1"x1" cop-cop cplg.comp.

=====



## METER HISTORY

## CHARGE OUTS

[illegible]