

APPLICATION No.: 29253

TAP CLEARED ✓

LOCATION: S.W. cor. Ruth St. &amp; Rodney Fr. Blvd.

OWNER: N.B. Housing Authority

MEASURES: 8"

C.I.C.L. Ductile Oct. 31, 1974

W from W line Rod. Fr. Blvd. (E)

154.0 ft.

N from S line Ruth St.

16.2 ft.

Line Service

F S  
I U  
R P  
E P  
L  
Y

Domestic # 29254

Nov. 12, 1999 Repaired leak on 8" fire supply by installing  
a 8" Smith Blair #226 Single Band Clamp Cplg. 7 1/2" W  
at a point 28 ft. S x tapping gate.

1 - 8" Smith Blair #226 Clamp cplg. 7 1/2" W  
-----

[illegible]

## CHARGE OUTS

[illegible]