

APPLICATION No.: 29331

TAP CLEARED

LOCATION: N.S. #311 Nemasket St. W x Alva St.

DATE

BEF.

AFT.

REMARKS

OWNER: Rita Farland

MEASURES: 1"-

Copper

Sept. 30, 1975

E from E line	Alva St.	6.0 ^{4.0} ft.
S from N line	Nemasket St.-	5.0 ft.
W from E line	House	15.0 ft.
S x S line	House	24.0 ft.

Main is 34 ft. S x N line.

Oct. 27, 75 Repaired leak - broken by D.P.W. Renewed from the curb stop to a point 5 ft. outside curb stop where a new curb stop was cut in to avoid digging the tap. This curb stop is buried in the on position located 5 ft. outside the curb stop. The original curb stop had to be relocated 2 ft. westerly.

5 ft. - 1" Copper tubing

1" Curb Stop

Caldwell Stop Box

- - -

[illegible][illegible]

CHARGE OUTS

[illegible]