

APPLICATION No.: 29549

TAP CLEARED

LOCATION: E.S. MacArthur Dr. N x Conway St.

OWNER: Marine Enterprises & Services

MEASURES: 6" Ductile Pipe Sept. 13, 1977

| | | |
|---------------|---------------|-----------|
| N from N line | Conway St. | 494.6 ft. |
| W from E line | MacArthur Dr. | 47.0 ft. |
| E from W line | MacArthur Dr. | 17.3 ft. |
| N from N line | Bldg. | 2.0 ft. |
| W from W line | Bldg. | 106.0 ft. |

Main is 48 ft. W x E line. F S

F S
I U
R P
E P
L
Y

1/8/07 Repaired 6" Fire Supply which was leaking in sidewalk
area. Stock: 1 - 227 wraparound 6" single band. Bento

[illegible]

CHARGE OUTS
