

#4

APPLICATION No.: 29609-8"

TAP CLEARED



LOCATION: S.S. Wright St. W x Hassey St.

OWNER: Sherman Co.

MEASURES: 8" Gate/ 6" Service Ductile April 7, 1978

W x 12" main gate on Wright St.

W x Hassey St. 87 ft.

See application card for measures of reducer,  
& bends.

Installed by Abream Const.

F S  
I U  
R P  
E P  
L  
YJan. 7, 1983 Repaired leak on fire supply - broken by  
Forte Bros. while laying sewer.

Installed a 6" Smith Blair #227 Clamp Cplg. 7½" W

Location: S x S line Wright St. 60 ft.

- - ½

DATE

BEF.

AFT.

REMARKS

[illegible]

## CHARGE OUTS