

APPLICATION No.: 29743

TAP CLEARED

11 44274

LOCATION: W.S. 273 R Highland St. N x Sutton St.

OWNER: Francisco Dos Santos

MEASURES: 1" -3/4" ins. Copper Dec. 15, 1978

~~S from S line Buchanan St. 116.3 ft.~~

E from W line Highland St. 7.0 ft.

S from S line House No. 273

N from N line Sutton St. 204.0 ft.

NOTE: Franklin Const. installed 3/4" Copper tubing from the curb stop to inside cellar. Reduced at curb stop. Main is 1 1/4 ft. E x W line.

Nov. 23, 1981: Renewed from curb stop to a point 1.5 ft. inside curbstop.(following order): 6" -1" copper; Reused 1" x 3/4" sweat cplg; 1.0 ft.-3/4" copper; 3/4" x 3/4" cop.-cop. comp. Cplg.

5/4/88: 1 - 1" x 1" cop to cop cplg. comp.

10/11/07 - Reamed tap - poor pressure

Stock: 2 ft - 1" copper tubing; 1 - 1" x 1" lead to cop adapt.

D. Monty

DATE

BEF.

AFT.

REMARKS

5/4/88: TAP REAMED

8818-2909

7-26-07

2:00

2007-300-2073

10/11/07

2007-410-5689

10/11/07

Tap reamed

[illegible]