

230 APPLICATION No.: #29971

LOCATION: E.S. Acushnet Ave. S x Wamsutta St.

OWNER: David Glicksman

MEASURES: 1" Copper Oct. 8, 1981

Measures of 1" Curb Stop

E x E line Acushnet Ave. 7.0 ft.
S x S line Wamsutta St. 409.7 ft.
S x S line Bldg. 1.3 ft.
W x W line Bldg. 9.4 ft.

This service is tapped off the 6" fire supply #17621. The fire supply was cut off at a point 18 ft. inside property with a line cap on the end. Work done W.C. Smith Const. & Son.

8' W x E Line
30"

TAP CLEARED

DATE

BEF.

AFT.

REMARKS

[illegible][illegible]

CHARGE OUTS

APPLICATION No.: 17621---6"

TAP CLEARED

LOCATION: Acushnet Ave. N.E. Cor. Merrimac

OWNER: Winston Mockeazil Co.

MEASURES: 6"

N from N line Merrimac 62.8 ft.
W from E line Acushnet Ave. 2.8 ft.
N from N line bldg. 12.0 ft.

F S
I U
R P
E P
L
Y

10/8/81 Fire supply was cut off at a point 18 ft.
inside property with a line cap on end. (because of leak)
Tapped fire supply with a 1" service # 29971 -
by W.C. Smith & Son Const.

Fire supply turned on 10/8/81 by Breton

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]