

1105 APPLICATION No.: 30197

TAP CLEARED 8528-0033

LOCATION: N.S. BRALEY RD., W X ACUSHNET AVE.

OWNER: Norman G. Audette

MEASURES: 1" Copper Nov. 27, 1984

W x W line Acushnet Ave. 1028.0 ft.

S x N line Braley Rd. 2.0 ft.

W x E line house 19.0 ft.

S x S line house 41.0 ft.

Main is 24 ft. S x N line.

Additional measures: W x W line Morton ave. (west entrance of school) 54 ft.

E x house service 1112 Braley rd. 50.6 ft.

7/8/85: Tap leaking. Installed new 1" corp. tap.

Stock: 1 - 1" corp. tap.

=====

7/9/07 NE Pressure Project .. tied into new 12" main. Renewed
from main to a point 7 ft. Stock: 7 ft. 1" copper tubing; 1" x 1"
cop-cop cplg., comp; 1" Fig. 413; 1" corp. tap Foreman: J Velez

- - - - -

METER HISTORY

[illegible]

CHARGE OUTS