

APPLICATION No.: #30202

TAP CLEARED



LOCATION: E.S. #10 No. Front St. N x Wamsutta St.

OWNER: Thorsteinn Gislason

MEASURES: 4" C.I.C.L. Ductile 11/6/84

N x N line Wamsutta St. 206.0 ft.
E x W line No. front St. 15.0 ft.

Main is 30 ft. W x E line.

NOTE: THIS GATE OPENS LEFT!!!

DATE

BEF.

AFT.

REMARKS

APPLICATION No.: 33440

TAP CLEARED

LOCATION: 10 Front St.

OWNER:

31-313

MEASURES: 8-10 Ductile Iron - Fire Supply 5/15/08
N from Wamsutta St 230.0
S from Hydrant 4.0
W from E line No. Front St 31.0
N from N line Building 2.0
N from S line Building 103.0
W from W line Building 178.0
Main to property line 18.0
Pipe inside property 258.3
N from Service Connection 27.0

5/1/08 - Inspection of fire supply - Percy Reynolds
Installation and materials supplied by Ace Asphalt (Fairhaven Exc)

5/15/08 - Pressure test by Percy Reynolds
1 hr @ 150 PSI - Passed

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

[illegible]

CHARGE OUTS

[illegible]