

APPLICATION No.: 30265

TAP CLEARED

LOCATION: W.S. Kingston St. N x Dawson S t.

OWNER: Philip Walski

MEASURES: 1" Copper Oct. 11, 1985

S x N line Dawson St. 2.0 ft.
E x W line Kingston St. 7.5 ft.
S x center of meter pit 8.5 ft.
North box for west side service.

Measures of 1" curb stop inside Kingston st .
S x S line house 17.0 ft.
E x E line house 27.0 ft.
E x W line Kingston St. 8.0 ft.
N x center of meter pit 77.6 ft.

2/24/09 - City crew tied existing water service into new 8" water
main in Kingston St, abandoned meter pit and killed service off
Dawson St. New measures - Foreman: Danny Perry

N from N line Dawson St 90.0
S from Hydrant 193.0
E from W line Kingston St 10.0
S from S line House 7.0
Main to property line 17.0
Pipe inside property 35.0
E from E line ~~HOUSE~~ 32.6

DATE

BEF.

AFT.

REMARKS

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS
			On Oct. 17, 1985 - a memo was sent to the Supt. of Water (Edward Rodrigues) from						
			Ast. Supt. (Arthur Pacheco) which read:						
			The service on east side of Kingston St. runs up in the street and the curb box was						
			installed in street. According to the Insp. Jos. Rodrigues & Meter Room Foreman,						
			George Pitta, these services are very poorly installed before the meter pit. We will not						
			turn on these services unless you tell us. cc: Muriel Bruneau						

CHARGE OUTS