


1248 APPLICATION No.: 30622

TAP CLEARED 

LOCATION: W .S. Cardinal St. N x Bluejay St.

OWNER: Lori A. Dumas

MEASURES: 1" Copper Dec. 2, 1986
N x N line Bluejay St. 119.0 ft.
E x W line Cardinal St. (using hyd. as line) 3.0 ft.
N x S line house 3.0 ft.
E x E line house 24.0 ft.

Main is 12 ft. E x W line.

March 20, 1987 Repaired leak at water main by installing a
6" x 1" Adams Repair Clamp. The 6" x 1" Saddle was removed.
6" x 1" Adams Repair Clamp 1" Corporation tap
1 ft. - 1" copper tubing 1 - 1" x 1" cop to cop cplg., comp.

DATE

BEF.

AFT.

REMARKS

METER HISTORY

CHARGE OUTS

[illegible]