

APPLICATION No.: 3070

TAP CLEARED

LOCATION: 40 No. Shawmut Ave. Cor. Willis

OWNER: Ellen A Hurley

MEASURES: $3/4''$

E from	Shawmut Ave.	33.2 ft.
S from N line	Willis	6.0 ft.
W from E line	House	8.6 ft.

9-3-99 Renewed from main to a point 2 ft. front the main. Stock: 2 ft. - 3/4" Copper tubing, 1 - 5/8"x3/4" lead to cop. adapt. XXS, 1 - 3/4" Corporation tap 1 - 6" x 3/4" Service Saddle.

Note: While at leak for 138 Willis St. Tap blow out, shut down main, install 1 - 6" x 3/4" Service saddle.

9/28/05 South Shore Utility renewed service from main to property line.

.....

[illegible]

CHARGE OUTS

[illegible]