

Service Killed

APPLICATION No.: 3080

TAP CLEARED

LOCATION: 128 Summer

OWNER: Albert C Neagus

MEASURES:

3/4"

S from

Maxfield

115.1 ft.

W from E line

Summer

6.9 ft.

N from S line

House

2.3 ft.

-----  
November 1, 1948 Replace lead service with 3/4" copper tubing  
from tap to property line.

26 ft. of 3/4" copper tubing 1 3/4" cop. to cop. stop

1 3/4" I.P.s. x 3/4" cop. coupling

-----  
September 11, 1969 Renewed from the property line to inside the  
cellar. All work done by owner and all stock supplied by owner's  
plumber.

36 ft. of 3/4" copper tubing 1 3/4" x 3/4" cop. to cop dplg.  
(at property line)

-----  
3/27/2012 Nelson Cardoso Killed this water service  
at the property line - Inspected by Percy

DATE

BEF.

AFT.

REMARKS



[illegible]

## CHARGE OUTS

[illegible]