

38 APPLICATION No.: 30841
LOCATION: S.W. cor. Exeter St. & Commonwealth Ave.

OWNER: Gerald Morrissey, Jr.

MEASURES: 1" Copper tubing Oct. 6, 1987

W x W line Commonwealth Ave. 27.0 ft.
N x S line Exeter S t. 10.0 ft.
W x E line house 12.4 ft.
N x N line house 25.0 ft.

Main is 7 ft. to curb stop

Dec. 19, 1988 removed the service saddle for cracked 4" main.
Replaced with a 4" x 1" Smith Blair #239 Clamp cplg. and a new
1" tap.

1/8/16 dig safe: from curb stop out 12 ft inside property line
3x12 loam
25ft box of 1" copper tubing
lead worker: Jarred Medeiros

DPI

TAP CLEARED

8851-0034

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]