APPLICATION No.: 3095		TAP CLEARED		
LOCATION: 166 Purchase St	DATE	BEF.	AFT. REMARKS	
OWNER:	4/1/08	Ream		
MEASURES; Apr 30, 1978  W X E Line Purchase St N X S Line House  10.2 ft  "Copper Service 10/30/2018 Lead Service Replacement Program Phase 1, Contractor P Gioioso & Son Type CU, Diameter 1in, Water pressure 100 Distance from main to curb stop (ft) 21 Distance from curb stop to meter (ft) 24 Distance from curb face to curb stop (ft) Depth of service (ft) 4.7 Total length of new pipe installed (ft) 24 Curb stop replaced: No size 3/4" Corporation replaced: No size 3/4" Ball valve replaced: Yes size 1" Remarks: 1-3/4 union installed 1 LF outside curb stop	it it in			

