

8/26/08 - West End Water Main Rehab Contract # 4 - Perrina Const  
Renewed water service from main to property line  
28 ft - 1" copper tubing; 1 - 1" corp tap; 1 - 1" curb stop;  
1 - 1" x 1" copper cplg. Inspected by Tim Ives, CDM

## METER HISTORY

[illegible]

## CHARGE OUTS