

68 APPLICATION No.: 31205
LOCATION: N.S. Angelica Ave. North E x Braley Rd.
OWNER: Braley Farms Assoc. LOT 131

TAP CLEARED



31-313

MEASURES: 1" copper tubing 1988

W x bound (front of house) 17.0 ft.
S x N line Angleica Ave. (N) 5.7 ft.
E x W line house 9.0 ft.
W x E line house 26.0 ft.
S x S line house 29.7 ft.

Water on April 18, 1989 Measures taken 4/2/93
Dec. 28, 1989

Labonne Bros. Cont. replaced frozen 1" service
Replaced copper from the main to a point 23.6 ft.
north from main. There ia a 1" x 1" cop to cop cplg.
6.6 ft. S x curb stop.
Main to curb stop 30.0 ft.
This service was very shallow. There was 3 ft. of
frost in the ground. The main is only 33" deep in
front of this address

M. Rose III

May 20, 1990 Pavao Const. of Rehoboth, Ma.
Due to lowering of 8" water main this service was
renewed from main to 2 ft. from main.
2 ft. - 1" copper tubing 1" x 1" cop to cop cplg., comp.
J. Rodrigues, Note: was frozen 1989

METER HISTORY

[illegible]

CHARGE OUTS