

MEASURES: 4" - 6"                      Ductile Pipe      Dec. 2, 1988

S x S line Grape St. 242.0 ft.

E x W line Field St.	12.0 ft.
----------------------	----------

N x S line Bldg. 46.5 ft.

E x E line Bldg.	27.5 ft.
------------------	----------

Main is 14 ft. E x W line.

FIRE SUPPLY

Increased to 6"4 ft. w x tapping gate valve.



DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

[illegible]

## CHARGE OUTS

[illegible]