

APPLICATION No.: 3126

TAP CLEARED

LOCATION: 238 County St

OWNER: 

31-313

MEASURES: 1" Copper Service

5/20/2019 - Lead Service Line Replacement Program

Phase 1, Contractor P. Gioioso and Son

Type CU, Diameter (in) 1, Water pressure 100

Distance from main to curb stop (ft) n/a

Distance curb stop to meter (ft) 19

Distance from curb face to curb stop (ft) 2.5

Depth of service (ft) 4.5

Total length of new pipe installed (ft) 19

Curb stop replaced: no, corporation replaced: no

Ball valve replaced: yes, size 1"

DATE


BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS



APPLICATION No.: 3126

TAP CLEARED

LOCATION: 238 County St.

OWNER: St. James, R.C. Church

MEASURES: 3/4" Copper June 12, 1878

S from S line Fair St. 29.7 ft.

W from E line County St. 3.5' ~~7.2 ft.~~

S from N line house 3.1 ft.

Oct. 14, 1952 Renewed from main to a point inside sidewalk inside
curb stop. Tap reamed

✓ 1-3/4" x 3/4" cop. to I.P. Fem/ Cplg. fig 413

1- 3/4" copper stop, fig 415

30 ft. of 3/4" copper tubing type K, soft

~~Marks~~~~Hardy~~~~Alves~~~~Mello~~✓ July 23, 1975 Renewed from the old curb stop to the
property line.

6 ft. - 3/4" Copper tubing 3/4" Curb stop

3/4" x 5/8" lead to copper adaptor XXS

Buffalo stop box
- - -

[illegible]

CHARGE OUTS

[illegible]