

#31782

LOCATION:

OWNER:

MEASURES: 3/4" Copper tubing Nov. 8, 1993

E x E line Cornell St.

N x S line Grant S t.

W x W line house

N x N line house

Main is 14 ft. N x S line.

5/20/08 - West End Water Main Rehab Contract # 4 - Perrina Const
Renewed water service from main to a point 6 ft
6 ft - 1" copper tubing; 1 - 1" corp tap; 1 - 1" x 3/4" reducer
Inspected by Tim Ives, CDM

TAP CLEARED

BEF.

REMARKS

[illegible]

CHARGE OUTS

[illegible]